

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1130:187 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Honeywell International Inc., 1500 West Dundee Road, Arlington Heights, IL 60004
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Models XLS757-3A, XLS757-5A, XLS757-6A, XLS757-7A and XLS757-8A, followed by suffix -MT, -MTW, -T or -TW horn strobes. Models XLSH-15ps, -15psw, -75ps, -75psw horn strobes. These devices are combinations of and audible signal appliance and a visual signaling appliances. Models with the letter "M" in the suffix are master units. Master units provide synchronization when used with slave units (models without "M" in the suffix). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Horn: 20-24 VDC
Strobe: -3A: 30 cd, -5A: 15 cd, -6A: 60 cd, -7A:15/75 cd, -8A: 110 cd
Strobe: -15ps, -15psw: 15cd, -75ps, -75psw: 75cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela ratings and UL label.

APPROVAL: Listed as audible/visual devices for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired applications and for indoor use only.

These appliances can produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to listee's Installation Instruction Manual for details.

XLf: *7125-1591:189 Formerly 7125-1388:214

*Rev. 05-25-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager